

DOCUMENT 00910

**ADDENDA
CONTRACT NUMBER 3-23-1
STOCKTON PORT DISTRICT
BUILDING DEMOLITION: 95 N PORT ROAD 14**

ADDENDUM NO. 1

April 14, 2023

This Addendum No. 1 ("Addendum") is dated the date set forth above and modifies certain Bidding Documents issued by the Port of Stockton ("Port") in connection with the Port's **BUILDING DEMOLITION: 95 N PORT ROAD 14, Contract No. 3-23-1**. All capitalized terms not otherwise defined herein shall have the meanings provided in the Bidding Documents. There are no other amendments to the Bidding Documents other than those which are expressly contained in this Addendum.

QUESTIONS / RESPONSES

1. In the bid documents, it asking to remove all building materials including the concrete. On the job walk we were asked to exclude the concrete removal.

RESPONSE: Exclude slab foundation removal from scope of work.

2. Is all the material going to be disposed of as RACM?

RESPONSE: Yes

3. Based on the survey amounts of debris contaminated by asbestos please confirm that all debris removed from site will be treated a Regulated Asbestos Containing Materials?

RESPONSE: Yes

4. Per the site visit we were able to see that the asbestos thermal system insulation around the boiler was exposed and damaged, will this material need to be removed under containment due to its friability and condition?

RESPONSE: Yes

**ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM NO. 1 FOR THE
STOCKTON PORT DISTRICT BUILDING DEMOLITION: 95 N PORT ROAD
14 – Contract No. 3-23-1**

Please sign and return this page only via email to bids@stocktonport.com to acknowledge receipt of Addendum No. 1 for this Project consisting of these **2 pages** in this Addendum.

X _____
Signature Date

Printed Name

Company Name

END OF DOCUMENT